

FIRE SAFETY CERTIFICATE

No. 266/24

Dated:04/06/2024

Certified that the **Bishop Kurialacherry Public School** (name of the building or premises) at **Champakulam P O, Alappuzha, Kerala** (address) comprised of four upper floors owned/ occupied by **Bishop Kurialacherry Public School** (name of the institution) have complied with the fire prevention and fire safety requirements in accordance with rule of State/ UT Fire Service Rules, and verified by the officers concerned of Fire Service on 03/06/2024 (date of inspection) in the presence of Cicily John , Chanthal's Educational Charitable Trust (name and addresses of the Manager/ Secretary or his representative) and that the building/ premises is fit for occupancy up to classes X (X/ XII) With effect from 04/06/2024 for a period of one year in accordance with rule and subject to compliance of specific conditions as appended:-

- 1.
- 2.
- 3.
- 4.



Issued on 04/06/2024 (date of issue) at Thakazhy (place) by

*Strike out whichever is not applicable.



Signature with Seal:

Name :

SURESH S

PEN No: 403607

Designation :

Asst. Station Officer

Fire & Rescue Station

Name & Address of Department Office:

Thakazhy Office 688562

To
Bishop Kurialacherry Public School
Champakulam, Alappuzha
Kerala-688505
 (Name & Address of the Institution)

ENDORSEMENT

The No Objection Certificate issued by Fire Service stand cancelled an annulled due to

.....
 (reasons to be recorded).

(Name and designation of the authorized signatory)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.



ഭരണഭാഷ- മാതൃഭാഷ

നം. സി/3591/19

ജില്ലാ ഫയർ ഓഫീസറുടെ കാര്യാലയം
ഫയർ ആന്റ് റെസ്ക്യൂ സർവീസസ്,ആലപ്പുഴ
E-mail: adoalp.frs@kerala.gov.in
തീയതി 19.07.2019

ജില്ലാ ഫയർ ഓഫീസർ,
ഫയർ ആന്റ് റെസ്ക്യൂ സർവീസസ്,
ആലപ്പുഴ

ഒ പ്രിൻസിപ്പാൾ
ബിഷപ്പ് കുര്യാളശ്ശേരി പബ്ലിക് സ്കൂൾ
ചമ്പക്കുളം

സർ,

വിഷയം : ഫയർ ആന്റ് റെസ്ക്യൂ സർവീസസ്, ആലപ്പുഴ- ഫയർ സേഫ്റ്റി സർട്ടിഫിക്കറ്റ്- സംബന്ധിച്ച്


സൂചന : (1) ജി.ഒ.(പി) നം.81/2017/എൽ.എസ്.ജി.ഡി, തീയതി 31/10/2017.
(2) ജി.ഒ.(പി) നം.82/2017/എൽ.എസ്.ജി.ഡി, തീയതി 31/10/2017.

കേരളാ പഞ്ചായത്ത് കെട്ടിട നിർമ്മാണ ചട്ടങ്ങളും കേരളാ മുനിസിപ്പാലിറ്റി കെട്ടിട നിർമ്മാണ ചട്ടങ്ങളും യഥാക്രമം സൂചന(1)ലെയും സൂചന(2)ലെയും ഉത്തരവുകൾ പ്രകാരം ഭേദഗതി ചെയ്തതിൽ കേരളാ മുനിസിപ്പാലിറ്റി കെട്ടിടനിർമ്മാണചട്ടങ്ങൾ 51(4എ)/ കേരളാ പഞ്ചായത്ത് കെട്ടിട നിർമ്മാണചട്ടങ്ങൾ 56(5) എന്നിവ പ്രകാരം 1000 ച.മീ. അടിത്തറ വിസ്തീർണ്ണം കവിയുന്ന അല്ലെങ്കിൽ പൊക്കം 15 മീറ്റർ കവിയുന്ന വിദ്യാഭ്യാസ വിഭാഗത്തിൽപ്പെട്ട കെട്ടിടങ്ങളുടെ സംഗതിയിൽ മാത്രമേ ഈ വകുപ്പിന്റെ എൻ.ഒ.സി. നൽകേണ്ടതുളളൂ.

കെട്ടിടത്തിൽ NBC part IV 2016 പ്രകാരം സുരക്ഷ ഒരുക്കിയിരിക്കുന്നതായി താങ്കൾ അറിയിച്ചിരിക്കുന്നു

താങ്കളുടെ അപേക്ഷ പരിശോധിച്ചതിൽ കെട്ടിടം 1000M² -ൽ താഴെ അടിത്തറ വിസ്തീർണ്ണം ഉള്ളതും 15 മീറ്ററിൽ താഴെ ഉയരമുള്ളതും ആണെന്ന് കാണുന്നു. ആയതിനാൽ ഈ വകുപ്പിൽ നിന്നും എൻ.ഒ.സി. നൽകേണ്ടതല്ലാത്തതാകുന്നു.

വിശ്വസ്തതയോടെ,


ജില്ലാ ഫയർ ഓഫീസർ,
ഫയർ & റെസ്ക്യൂ സർവീസസ്,
ആലപ്പുഴ

